

The Building Life Safety Checklist

The below is intended to be used by Building Administrators or their designees, Building Managers or Department Heads to assure compliance of the building space under their control with Life Safety Code requirements.

Name:	
Building Name:	Date Checked/Fixed
All exit routes, including all corridors, stairwells, and doorways, are free from all obstructions to full, instant use.	
No storage within 18" of level of sprinkler heads, or within 24" of un-sprinkled ceilings.	
No electrical equipment is operated in corridors on a permanent basis.	
All exit signs are illuminated and visible.	
All emergency equipment is plainly visible and completely unobstructed, to include:	
Fire Extinguishers	
Fire Alarm Pull Stations	
Fire Connections	
Emergency Eyewash Stations	
Safety Showers	
Electrical Panels	
In areas equipped with smoke/heat detectors or fire sprinklers, all ceiling tiles are in place and intact. All penetrations are sealed.	
Wall coverings, such as posters or decorations, are flame retardant or cover less than 10% of the surface area of the wall.	

If you need help determining whether or not an issue constitutes a violation or obtaining compliance, you can

- e-mail a completed copy of this checklist to remmons@uab.edu **OR**
- send it by campus mail to
 - Robert Emmons
 - CH 19 Room 445
 - Zip 2041

We strongly recommend keeping a copy for your files.